



491 East Princess Street
York, PA 17403
Ph.: (717) 843-4311 / (877) 905-1111 Fax: (717) 854-4462
www.unitedcoolair.com
Email: uca@unitedcoolair.com

April 1, 2010

SB-063

To: United CoolAir Distribution

Subject: **MiniCool Systems**

APPLICATION NOTICE

The United CoolAir MiniCool systems have provided many opportunities to solve problems for many customers over the past couple of years. However, one of the applications that they should not be utilized for is computer room applications. This was communicated prior in Sales Bulletin SB-037.

Please note the following application criteria:

- a. MiniCool systems are designed for comfort cooling applications only.
- b. The traditional air flow on these ductless systems is lower than the levels typically required for server rooms or telecommunication rooms.
- c. The coils have been designed for comfort cooling and not the usual sensible cooling only loads experienced in a precision cooling environment.
- d. The evaporator bearings have been designed for the duty that they would see in a comfort cooling application, not the more prolonged duty they would see in a precision cooling application.
- e. There are also some control functions that are built into the microprocessors that do not lend themselves to the extended run periods required for precision cooling.

As always, if you have any questions please contact us.

A handwritten signature in cursive script that reads "Rod Beaver".

Rod Beaver
Vice President, Sales & Marketing